



WARNING

This Building Contains a FlameGuard®
CPVC Fire Sprinkler LIFE SAFETY SYSTEM

DO NOT ALLOW CHEMICALS OR CABLES TO COME IN
CONTACT WITH CPVC FIRE SPRINKLER SYSTEM!

** Protect all Orange CPVC Piping Products from any
unmixed and uncured Spray Foam Chemicals**

**IF YOU DAMAGE THIS SYSTEM YOU WILL BE HELD
RESPONSIBLE FOR ALL DAMAGES**

For additional information contact the General Contractor or Fire Sprinkler System Installer
-OR-

Spears® Technical Service Department at 1-800-862-1499

FLWW-7-0422



ADVERTENCIA

**Este Edificio Contiene un SISTEMA DE SEGURIDAD
DE VIDA FlameGuard® de CPVC de Rociadores
Contra Incendios**

¡NO PERMITA QUE QUIMÍCOS O CABLES ENTREN EN
CONTACTO CON ESTE SISTEMA DE CPVC PARA
ROCIADORES CONTRA INCENDIOS!

** Proteja Todo Producto de Tubería de CPVC Color
Naranja de Cualquier Producto Químico de Espuma en
Aerosol Sin Mezclar y Sin Curar**

**SI USTED DAÑA ESTE SISTEMA USTED SERÁ
RESPONSABLE POR TODOS LOS DAÑOS**

Para obtener información adicional, comuníquese con el Contratista General,
ó el Instalador del Sistema Contra Incendios

-Ó-

con el Departamento de Servicio Técnico de Spears® al 1-800-862-1499

FLWW-7-0422

Notice

This building contains a CPVC fire sprinkler system. This CPVC fire sprinkler system is a Life Safety Assembly and must be treated carefully. Please read the following before any activity which could contact this system:

CPVC piping components may be damaged by certain substances and construction practices.

- DO NOT stack, support, hang equipment, or hang flexible wire/cable, especially communications cable, or other material on the fire sprinkler system.
- ONLY system compatible materials including, but not limited to solvent cements, caulks, sealants, cutting oils and thread pastes as noted by the CPVC fire sprinkler piping system manufacturer's installation instructions should be used in contact with this system.
- DO NOT expose CPVC products to incompatible substances, such as cutting oils, non-water based paints, packing oils, traditional pipe thread paste and dope, fungicides, termiticides, insecticides, detergents, building caulks, adhesive tape, solder flux, flexible wire/ cable (with special consideration for communications cabling), and non-approved spray foam insulation materials.
- DO NOT expose CPVC products to edible oils, solvents, or glycol-based anti-freeze fluids.
- DO NOT expose CPVC products to open flame, solder, and soldering flux.
- DO NOT handle CPVC products with gloves contaminated with oils (hydrocarbons) or other incompatible materials.

Failure to follow this notice may cause cracks or fractures to develop in CPVC products resulting in property damage due to leaks or flooding. The presence of any visible cracks may require partial or full system replacement. For additional information contact the general contractor or the fire sprinkler system installer.



**FOR ADDITIONAL INFORMATION CONTACT
SPEARS® MANUFACTURING COMPANY AT 1-800-862-1499**

Important Information with Regards to Your CPVC Fire Sprinkler System

CONGRATULATIONS! This building contains a state-of-the-art FlameGuard® life safety system. Your CPVC fire sprinkler system will enhance the safety and security of your building when properly cared for. CPVC Fire Sprinkler Products resist attack from a wide range of chemicals that are corrosive to metallic piping. As with any piping material, there are certain chemicals that can be detrimental to CPVC. Occasionally, some of these chemicals may be found in some construction products, site preparations and building maintenance. There are certain things that you need to be mindful of in caring for or working around your CPVC fire sprinkler system.

Keep your system clear from contact with the following products and chemicals unless product labels state materials are compatible with CPVC:

NOTICE	
Ordinary Considerations	Property Maintenance Services
Cleaning Products/Detergents Oils/Lubricants/Greases Rubbery Materials	Fungicides Mold Remediation Chemicals/Termiticides/Insecticides
For Hired Contractors & Do-It-Yourselfers	
Corrosion Inhibitors Glycol-based antifreezes Solder Flux Thread Sealants Flexible Cable/Wiring (especially communications cabling) Caulks/Mastics Adhesive Vinyl/Electrical Tape Non-Water Based Paint Paint Thinners Wood Finishes/Varnishes	

You should also avoid the following:

- Sitting, standing, hanging, leaning, or resting anything on the pipe, fittings, and sprinkler heads
- Grounding electrical wiring to the pipe or fittings
- Ambient temperatures below 40°F/4°C where your fire sprinkler system is located. (Unless an approved compatible antifreeze or insulation method is installed.)
- Hot work around the pipe, i.e. blow torches, soldering, etc.

Be certain this document is reviewed and understood by anyone working on or around your CPVC life safety system. If you have any questions or need assistance on chemical compatibility with your CPVC fire sprinkler system, contact the manufacturer listed on the pipe.

Proper care will help your CPVC fire sprinkler system provide protection for years to come.



FOR ADDITIONAL
INFORMATION CONTACT
SPEARS® MANUFACTURING
COMPANY AT 1-800-862-1499